

eco-INSTITUT, Schanzenstr. 6-20, D-51063 Köln

Hilti Entwicklungsgesellschaft mbH  
Mrs. Cintia Chagas de Oliveira  
Hiltistraße 6  
86916 Kaufering

Dear Mrs. Chagas de Oliveira,

based on the evaluation of Test Report No. 55493-A004 II and dated 2020-09-29, the testing results of the product **Hilti Firestop Coating CP 673** manufactured by **Hilti Entwicklungsgesellschaft mbH** comply with the requirements of

- VOC content ASTM D 2369 – 10 and South Coast Air Quality Management District (SCAQMD) Rule 1113

This criteria meets the requirements for low-emitting **Paints and Coatings** in credit EQc2 of the LEEDv4 Rating System and the LEEDv4.1 Rating System.

Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

VOC content	VOC Limit Value*
27.19 g/L	150 g/L

\* VOC Limit Value for "Fire-Proofing Coatings" (SCAQMD 1113, 02/2016)

Cologne, 2020-11-13



Marc-Anton Dobaj, M.Sc. Crystalline Materials  
(Project manager)